



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND RESCUE SERVICES UT LADAKH

(e-mail-soto-igp@police.ladakh.gov.in)

(Office Phone Number.01982-260888)

Number: - F&RS/Dir/NOC/2025- 12405-406

Dated: - 18/07/2025

Subject: Fire NOC of Imamiya Mission School at Chuchot, Leh.

The report has been submitted by Deputy Director, Ladakh regarding the inspection of the instant School building wherein the spot visit has been conducted by DFO Fire and Rescue Services Station, Leh. The detailed report of the School building is as under:

Location/ Accessibility:

The School building is constructed at Chuchot, Leh. It is located at latitude 34.046744 and longitude 77.631696. The site is approximately 15 Kms away from Fire and Rescue Service Station Leh and it takes approximately 22 minutes to reach the site which is approachable for fire appliances.

Detail of building:

The school building has four blocks. The detail of the blocks is as under:

1st Block: It is two storied building having two stair cases. In the ground floor there is Laboratory room, Seniors Digital two rooms and Computer room. There is one window in each class rooms and size is 11x7 feet. Two side of the window have provision to open. 1st floor has Chairman Office, Management office, staff room and meeting room.

2nd Block: It is a two storied building having two stair case. There are 5 class rooms in each floor and one window in each rooms. The window size is 5x7ft. Two side of the window has provision to open. The height of the window from ground level is 2ft.

3rd Block: It is two storied building having two stair cases. There are 04 class rooms in each floor and one window in each class rooms. The window size is 6x5 feet and one side of the window has provision to open. The height of the window from ground level is 2 ft.

4th Block: It is single storied building with Auditorium hall sized 72x42 sr. ft. There are 3 window in the hall sized 5x7ft and three exits.

There are 407 students and 64 staff in the school. Accordingly, the following Minium firefighting installation are required and applied.

The following Fire Safety equipment are installed in school Building:

1. 17 number of fire extinguishers ABC Type 5kg capacity are installed in the school building.
2. 25 thousand liters underground reserve water tank is installed in the school premises.
3. 01 number of plastic water tank 1000 liters' capacity overhead of the building and 07 number plastic tank 500 liters' capacity on the school ground.
4. 01 number of submersible bore pump is in the school building premises.
5. 9 number of sand bucket is installed in the school premises.

As per the field report, the above equipment were found to be in place. **FIRE NOC** is given in the favour of **Imamiya Mission School at Chuchot, Leh** for period of **One year** from the issuance.

Copy to:

1. Principal, Imamiya Mission School at Chuchot, Leh for information.
2. Deputy Director, F&RS, Ladakh for information.
3. Office file.


DIRECTOR
FIRE & RESCUE SERVICE
UT LADAKH